

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Memo/ St. Joseph/ 2025-26

Dated: 28.06.2025

It is certified that an inspection team headed by Dr. Ramesh Prasad Medical Superintendent (Name of Officers with designation) from C.H.C. Dhanapur chandauli U.P. PHED inspected the St. Joseph School Kamalpur Dist. chandauli U.P. (Name & Address of the school) on 15.06.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no SBPL/DW/1001589 dated 19/06/2025 Of Silkron Biotech Pvt Ltd (PHED Lab) certified that the St. Joseph School Kamalpur Chandauli (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 27.06.2028

आधिकारिक  
समुदायिक सारथ केंद्र  
धनापुर चंदौली

Signature with Seal:

Name : Dr. Ramesh Prasad

Designation : M.S. Dhanapur

Name & Address of office/Department:-

To

... St. Joseph School (71887)  
... Kamalpur chandauli U.P.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



# SILKON BIOTECH PVT LTD

(NABL Accredited Laboratory)

CIN NO.U74999UP2017PTC091011 | GST IN : 09AAYCS2616M1ZJ

Silkon House, Lane No. 3, Maa Laxmi Nagar, Kanchanpur, D.L.W. Varanasi - 221005

Revision No.00

Format No. SBPL/QSF/11-01/00

## TEST REPORT

### NAME & ADDRESS OF CUSTOMER

Issued to - St. Joseph School (71887)  
Kamalpur, Chandauli

ULR No. TC859423000000491F

Job Order No. SBPL/DW/1001589

Report Issue Date. 23/09/2023

### Water Sample Analysis Report

Type of Sample	:	Drinking Water
Date of Sampling	:	19/09/2023
Test Start Date	:	19/09/2023
Test End Date	:	23/09/2023
Sampling Done By	:	Sample Provided by Customer
Sampling Method	:	IS:3025 Part-1
Sample Code	:	DW- 280
Sample Quantity	:	3 Lit
Sampling Location	:	RO Water

### Test Result

S. No.	Parameter	Unit	Result	Limits as per IS 10500:2012		Test Method
				Acceptable	Permissible Limits	
1.	Colour	Hazen	<5	5	15	IS:3025 (Part-04)
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025 (Part-05)
3.	pH	-	7.56	6.5 – 8.5	No Relaxation	IS:3025 (Part-11)
4.	Turbidity	NTU	<1	1	5	IS:3025 (Part-10)
5.	Total Dissolved Solids	mg/l	68.27	500 mg/l	2000 mg/l	IS:3025 (Part-16)
6.	Chloride (as Cl)	mg/l	17.99	250 mg/l	1000 mg/l	IS:3025 (Part-32)
7.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/l	48.0	200 mg/l	600 mg/l	IS:3025 (Part-23)
8.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	42.0	200 mg/l	600 mg/l	IS:3025 (Part-21)
9.	Calcium (as Ca)	mg/l	8.82	75 mg/l	200 mg/l	IS:3025 (Part-40)
10.	Magnesium (as Mg)	mg/l	4.86	30 mg/l	100 mg/l	IS:3025 (Part-46)
11.	Fluoride (as F)	mg/l	ND {LOD=0.1 mg/l}	1 mg/l	1.5 mg/l	IS:3025 (Part-60)
12.	Iron (as Fe)	mg/l	ND {LOD=0.1 mg/l}	1 mg/l	No relaxation	APHA 23 <sup>rd</sup> Edi.

Note- ND Means Not Detected

Checked By

Authorized Signatory  
Uttam  
(Assistant Q.M.)  
Varanasi

\*\*\*END OF REPORT\*\*\*

#### Note:-

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- The Result Tested as per Requirement of Customer.
- This Report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
- Sample will be disposed after 15 days from date of Issue of Test Report.



TC-8594



# SILKON BIOTECH PVT LTD

(NABL Accredited Laboratory)

CIN NO.U74999UP2017PTC091011 | GST IN : 09AAYCS2616M1ZJ

Silkon House, Lane No. 3, Maa Laxmi Nagar, Kanchanpur, D.L.W. Varanasi - 221005

Revision No.00

Format No. SBPL/QSF/11-01/00

## TEST REPORT

### NAME & ADDRESS OF CUSTOMER

Issued to - St. Joseph School (71887)  
Kamalpur, Chandauli

ULR No. TC859423000000491F

Job Order No. SBPL/DW/1001589

Report Issue Date. 23/09/2023

### Biological Water Sample Analysis Report

Type of Sample	:	Drinking Water
Date of Sampling	:	19/09/2023
Test Start Date	:	19/09/2023
Test End Date	:	23/09/2023
Sampling Done By	:	Sample Provided by Customer
Sampling Method	:	IS:3025 Part-1
Sample Code	:	DW- 280
Sample Quantity	:	3 Lit
Sampling Location	:	RO Water

### Test Result

S. No.	Parameter	Result	Limits as per IS 10500:2012		Test Method
			Requirement		
1.	<i>E. Coli</i>	Absent	Shall not be detectable in any 100 ml Sample		IS:1622 (1981 RA 2019)
2.	Total Coliform	Absent	Shall not be detectable in any 100 ml Sample		IS:1622 (1981 RA 2019)

Checked By

Authorized Signatory  
Vinay Kumar Rai  
Varanasi

\*\*\*END OF REPORT\*\*\*

#### Note:-

1. The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
2. The Result Tested as per Requirement of Customer.
3. This Report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Sample will be disposed after 15 days from date of Issue of Test Report.



TC-8594